

SubDevice.SetParameters

Setting device parameters

Синтаксис

```
SubDevice.SetParameters({Host: host, Port: port, other})
```

Название	Пример	Описание
host	"192.168.0.100"	type: string IP address or domain name to connect to equipment
port	8080	type: number connection port
other		type: - other parameters characterisric of a driver. If a parameter is not indicated, previous or deafult value is saved
На выходе		
Boolean		type: Boolean Success rate

Пример

```
var l_oDevice = module.GetDevice("KNX"); //Getting a device  
var l_oSubDevice = module.AddSubDevice("SubDevice 1", l_oDevice); //creating  
a subdevice  
l_oSubDevice.SetParameters({Host: "215.110.10.22", Port: 8080});
```

Driver properties can be seen here: [Свойства драйверов](#)