

## Device.SetFeedback()

to write the value in the driver feedback channel. The channel has to be created in advance in Project Device Panel. It is used to display data received from equipment at work of scripts.

### Syntax

```
Module.GetDevice(driver).SetFeedback(name, value)
```

<b>input</b>	<b>sample</b>	<b>description</b>
driver	"Driver 1"	type: string the driver name in the iRidium project
name	"Channel 1"	type: string the feedback channel name (Feedbacks)
value	"data"	type: string, number the string or number you to be written in the channel
<b>output</b>		
successful or not		type: Boolean successful

### Example:

```
B.getModule(ModuleID);  
Module.GetDevice("MyDevice").SetFeedback("Value 1", 100);
```